# Certificate

valid until 31.12.2011

Passivhaus Institut Dr. Wolfgang Feist Rheinstraße 44/46 D-64283 Darmstadt

Component suitable for

Passive Houses: Window Frame

Manufacturer: Drewexim Sp. z o.o. PL-75-137 Koszalin

Name of product: Euro88 PHI

# The following criteria were checked to award the certificate:

The criteria are valid for the cool temperate climate.

#### Passive House comfort criterion:

Under standard conditions (use of glazing with  $U_g = 0.7 \text{ W/(m}^2\text{K})$ , width of window 1.23 m, height of window 1.48 m) the U-Value of the window fulfils the following condition:

$$U_w = 0.79 \le 0.80 \text{ W/(m}^2\text{K)}$$

## Thermal data of the window frame:

Frame	jamb	sill
<b>U</b> <sub>f</sub> [W/(m <sup>2</sup> K)]	0.74	0.72
Width [mm]	97	117

Spacer	Superspacer Tri-Seal	
$\Psi_g$ [W/(mK)]	0.032/0,033	

#### Conditions specific for Passive Houses:

The suitability for Passive Houses was checked only with the spacer denoted above; thermally worse spacers, especially those made of aluminium, lead to significantly higher thermal losses.

# <u>Installing the window suitable for Passive House:</u>

Including all thermal bridge effects, the window fulfils the condition

 $U_{w,installed} \leq 0.85 \text{ W/(m}^2\text{K)}$ 

if the window is installed into wall constructions suitable for Passive Houses (brick wall with thermal insulation, light weigth wooden construction and form work for concrete of polysterene) according to the drawings of details given in the appendix.

## The certificate has to be used as follows:

Component suitable for Passive Houses Dr. Wolfgang Feist



# Window frame:

 $U_f = 0.74 / 0.72 \text{ W/(m}^2\text{K})$   $\Psi_g = 0.032/0,033 \text{ W/(mK)}$ Width = 97/117 mm